

Certificate of Compliance

Date: 06/09/2024

Code or Series: GM-EMC-FT

Product Name/Description: Metal Feed Through Gland for screened cable

These products have been manufactured to a Rating of IP68, with a material of bright nickel plated extruded brass gland body and compression head.

Manufactured to BS EN 50262 and Brass Extrusion BS 2874 CZ121 3Pb

Technical Manager

Dean Lipscombe

Signed



Disclosure: The information provided is to the best of our knowledge and is current at date of issue. Firstflex reserves the right to make changes and modify this document as they see fit.