

Socket Outlets – Prestige P2000 Series

Prestige P2000 sockets have been designed with larger than standard 'soft-switch' mechanisms. They are particular of benefit for segments that find regular switches difficult to use. For example retirement villages, nursing homes, disabled areas, vision impaired, etc. The stylish large mechanism can also appeal to those that are familiar with European switch designs. Although the twin sockets are assembled on larger plates, they still have the flexibility of being installed or retro fitted onto most common mounting accessories.

Single Phase Socket Outlets shall:

- Comprise a 10A rocker operated switch and three-pin plug base with flat Earth pin, mounted in a two-piece, moulded, impact-resistant polycarbonate, gloss finish flush plate with a full cover plate similar to Clipsal Prestige Series
- Have a large actuator switch dolly similar to Clipsal Prestige Series
- Be manufactured in accordance with AS/NZS3100, AS/NZS3112 and AS/NZS3133
- For special purpose socket outlets, be provided with 15A and 20A mechanisms and appropriate sockets
- Comprise two switches and two sockets within a common large size flush plate similar to Clipsal P2025/2 Series, for double socket outlets
- Fit within standard mounting accessories, unless accessory includes an extra switch
- Be flush mounted within a Clipsal 157 Series wall box having adjustable metal fixing lugs where located in masonry walls
- Be flush mounted within a 155 Series metal bracket fixed to a stud or noggin, where located in stud partitions
- Be flush mounted within a 154 Series metal wall clip if unable to be fixed to a stud, noggin or masonry
- Where required, plates to be engraved with circuit identification labelling
- Be of same type and manufacture as switches
- Be fitted with a Clipsal 90B insulating shroud where located within close proximity to metal framework
- Where fire ratings of walls are required, Clipsal 157/1F or 157/2F (for cavity walls) and F157/1 (for masonry walls) fire rated wall boxes are to be used and installed as per manufacturer's instructions. Wall boxes are to be tested to AS1530.4 and AS 4072.1
- Where acoustic ratings are required for sound transmission, Clipsal 157/1F or 157/2F (for cavity walls) and F157/1 (for masonry walls) acoustic rated wall boxes are to be used and installed as per manufacturer's instructions. Wall boxes to be tested in accordance with AS1191, AS1276, AS1045, for sound transmission and achieve a rating of up to Rw50 or STC50 using various Clipsal accessories and wall materials
- Be labelled NO RCD PROTECTION on outlets connected to circuits which are not protected by a residual current device
- Be fitted with manufacturer's snap-on paint shield (P2000PP for standard plate sizes or P2000/2PP for oversized plates) to provide protection during painting.