

Certificate Number: AZ 69026660

Page: 0001



CERTIFICATE OF APPROVAL

Authorised marking: TUV-026660-EA

TÜV Rheinland Australia Pty Ltd "Electrical Product Safety Certification (EPSC) Scheme", accredited by JAS-ANZ in accordance with ISO/IEC 17065, has issued this certificate under the Gas and Electricity (Consumer safety) Act 2017 as a declared Recognised External Approval Scheme (REAS). The electrical equipment described hereunder has been evaluated and found to be electrically safe at the time of certification. It is a requirement that all equipment supplied under this certificate shall be identical to the equipment as certified. The certificate holder shall place the above mentioned authorised marking on the product. The certificate holder may use the Regulatory Compliance Mark (RCM) provided all the requirements of AS/NZS 4417.1 & AS/NZS 4417.2 applicable to the article are fulfilled.

CERTIFICATE HOLDER:

Zhejiang Benyi Electrical Co., Ltd.
Wenzhou Bridge Industrial Zone,
Beibaixiang Yueqing
Zhejiang
P.R. China

DESCRIPTION OF EQUIPMENT

Declared class:

MINIATURE OVERCURRENT CIRCUIT - BREAKER

Product:

DC Miniature Circuit Breaker (suitable for isolation)

Trade Name / Manufacturer:

ZJBENY (Logo)

Model Number:

BB1-63 ; BB1F-63

Ratings:

Ui = 1200V, Uimp = 6kV, Reference temperature 40°C
BB1-63: IP20; BB1F-63: IP65; Ue = 300Vdc (1P)
Ue = 600Vdc (2P); Ue = 900Vdc (3P); Ue = 1200Vdc (4P)
In = 3/4/6/10/13/16/20/25/32/40/50/63A ; Ics = Icu = 6kA
Instantaneous tripping curve: li = 5In (Type B)
li = 10In (Type C), li = 14In (Type K), li = 20In (Type D)

Standard:

AS/NZS IEC 60947.2:2015
AS/NZS IEC 60947.1:2015

Issue Date:

24/11/2022

Expiry Date:

24/11/2027

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

Grant Li



www.jas-anz.org/register