

DECLARATION OF COMPLIANCE FOR LUMINAIRES

Issuer: Evolt Pty Ltd
Address: U5/105a Vanessa Street
Kingsgrove, NSW 2208, Australia



PRODUCT INFORMATION

BRAND	MODEL	SKU
Ektor	EV-LED FIRE-SM-ADV-IP65-B-DA	11549

COMPLIANCE

2293 Report	WTF22F06121008N
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3

OPERATIONAL INFORMATION

IP Rating	IP65
Working Temp Range	0 to 40 °C
Input voltage	230Vac
Input Frequency	50 Hz
Electrical Rating	Class II
Driver Type	DALI DT1 Emergency
Product Type	EM LIGHT NETWORK

EMERGENCY INFORMATION

Emergency Mode	Non-Maintained
Emergency Duration	90 mins
Emergency Classification	C0:D63, C90:D63
Replacement Battery Code	18096

DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

Title: Managing Director **Date:** 05/01/22

Signature:

J Newell