

## DECLARATION OF COMPLIANCE FOR LUMINAIRES

**Issuer:** Evolt Pty Ltd  
**Address:** U5/105a Vanessa Street  
Kingsgrove, NSW 2208, Australia



## PRODUCT INFORMATION

| BRAND | MODEL                        | SKU   |
|-------|------------------------------|-------|
| Ektor | EV-LED FIRE-SM-ADV-IP65-B-LK | 11551 |

## COMPLIANCE

**2293 Report** WTF22F06121008N

**Standards** AS/NZS 60598.1  
AS 60598.2.22  
AS/NZS 61347.1  
AS/NZS 61347.2.13  
AS CISPR 15  
AS/NZS 2293.3

## OPERATIONAL INFORMATION

|                    |                                  |
|--------------------|----------------------------------|
| IP Rating          | IP65                             |
| Working Temp Range | 0 to 40 °C                       |
| Input voltage      | 230Vac                           |
| Input Frequency    | 50 Hz                            |
| Electrical Rating  | Class II                         |
| Driver Type        | Wireless (IEC62386-104) with DT1 |
| Product Type       | EM LIGHT NETWORK                 |

## EMERGENCY INFORMATION

|                          |                 |
|--------------------------|-----------------|
| Emergency Mode           | Non-Maintained  |
| Emergency Duration       | 90 mins         |
| Emergency Classification | C0:D63, C90:D63 |
| Replacement Battery Code | 18096           |

## DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

**Title:** Managing Director **Date:** 05/01/22

**Signature:**

*J Newell*