

SUPPLIER DECLARATION OF CONFORMITY (SDoC)

In accordance with ISO/IEC 17050-1:2004

SDoC Identification Number¹:	HAL-SDOC-LED440LED441LED442LED444LED445
--	---

Issuer Details			
Name² (of New Zealand manufacturer or importer):	Halcyon Lighting Ltd	Contact Address:	13 Lady Ruby Drive, East Tamaki, Auckland 2013
NZ Company No.:	114999		
Telephone:	09 273 9177	Email:	info@halcyon.co.nz

Medium Risk Article – Details ³			
Name, type, rating, brand, model, batch/serial numbers as applicable			
Type:	LED Batten	Brand:	Halcyon
Model	Rating		
LED440-W457KA	220-240V~50/60Hz, <42W, 4000K/5700K, IP20, Class I luminaire, Ta -20..+40°C		
LED441-W457KA LED441-W457K-D	220-240V~50/60Hz, <42W, 4000K/5700K, IP20, Class I luminaire, Ta -20..+40°C		
LED442-W457KA LED442-W457K-D	220-240V~50/60Hz, <42W, 4000K/5700K, IP20, Class I luminaire, Ta -20..+40°C		
LED444-W457KA LED444-W457KA-D	220-240V~50/60Hz, <42W, 4000K/5700K, IP20, Class I luminaire, Ta -20..+40°C		
LED445-W457KA LED445-W457KA-D LED445-W457K-DD	220-240V~50/60Hz, <42W, 4000K/5700K, IP20, Class I luminaire, Ta -20..+40°C		
LED441-W457K-EM	220-240V~50/60Hz, <42W, 4000K/5700K, IP20, Class I luminaire, Ta -20..+40°C		
LED442-W457KA-EM	220-240V~50/60Hz, <42W, 4000K/5700K, IP20, Class I luminaire, Ta -20..+40°C		
LED444-W457KA-EM	220-240V~50/60Hz, <42W, 4000K/5700K, IP20, Class I luminaire, Ta -20..+40°C		
LED445-W457KA-EM	220-240V~50/60Hz, <42W, 4000K/5700K, IP20, Class I luminaire, Ta -20..+40°C		

The Medium Risk Article listed above, fully complies:			
With cited standard(s), as listed ⁴ :			
Standard No. & Issue Year	Edition / Amendment	Standard Title	AS/NZS ZZ Modified
AS/NZS 60598.1	2017+A1:2017+A2:2020	Luminaires – Part 1: General requirements and tests.	☐ Yes ☐ No ☒ N/A
AS/NZS 60598.2.1	2014+A1:2016+A2:2019	Luminaires – Part 2.1: Fixed general purpose luminaires.	☐ Yes ☐ No ☒ N/A
AS/NZS 61347.1	2015+A1:2017	Lamp controlgear, Part 1: General and safety requirements	☐ Yes ☐ No ☒ N/A
AS/NZS 61347.2.13	2014+A1:2016	Lamp controlgear - Part 2.13: Particular requirements for d.c. or a.c. supplied electronic controlgear for LED modules.	☐ Yes ☐ No ☒ N/A
AS/NZS 2293.3	2018	Emergency lighting and exit signs for buildings, Part 3: Emergency luminaires and exit signs.	☐ Yes ☐ No ☒ N/A
OR Conformity Cooperation Agreement (CCA) ⁵			
Complies with CCA:	☐ Yes ☒ No		
OR EESS Registration ⁶			
Registered on EESS:	☐ Yes ☒ No	EESS Equipment #:	

SUPPLIER DECLARATION OF CONFORMITY (SDoC)

In accordance with ISO/IEC 17050-1:2004

Names and addresses of any Evaluating/Testing/Certification organisation or body used			
Name:	Waltek Services (Ningbo) Co., Ltd.	Address:	1/F., No.6, Building, No.1177, Lingyun Road, Ningbo Hi-Tech Zone, Yinzhou District, Ningbo, Zhejiang, China
Name:	SAA Approvals	Address:	Unit 5, 20 Rivergate Place, Murarrie, QLD 4172, Australia

Test Reports & Supporting Documentation		
Supporting document(s) used, to show how compliance with the declared standard(s) is achieved:	Report / Certificate Ref No.(s):	Issue Date(s):
Test Report AS/NZS 60598.1, AS/NZS 60598.2.1, , AS/NZS 61347.1, AS 61347.2.13	SAA2441153	17/09/2024
Test Report AS/NZS 2293.3	WTS19F08056116N	08/10/2019
Reference to any management quality system involved: Additional Information ⁷ :		

Declaration – Signed for and on behalf of:	
Halcyon Lighting Ltd	
I hereby declare that the above specified fittings or electrical appliances comply with the requirements of Regulation 83 of the Electricity (Safety) Regulations 2010	
Name & Position⁸:	Patrick O'Malley, Product Manager
Signature:	
Date:	14/07/2026
Issuer ID (as affixed to article):	HALCYON